

**Summary of Reasons Supporting the Adoption of the Proposed Amendments to the  
Alabama Department of Environmental Management's (ADEM) Administrative Code  
ADEM Water Division - Water Supply Program, Division 335-7**

The Department is proposing to amend its Water Supply regulations in division 335-7, chapters 335-7-2; 335-7-4; 335-7-5; 335-7-6; 335-7-7; 335-7-10; 335-7-11 and 335-7-14 to make technical and administrative clarifying changes.

**INDEX OF PROPOSED CHANGES TO DIVISION 7**

**Chapter 335-7-2**

Page	Rule	Rationale
2-4	335-7-2-.03(4)(g)	Clarifies when 14 day timeline begins.
2-5	335-7-2-.03(5)(e)	Clarifies when 14 day timeline begins.
2-7	335-7-2-.04(1)	Administrative changes.
2-18	335-7-2-.08(1)	Administrative change.
2-24	335-7-2-.09(2)(a)	Removed daily sample requirements to be consistent with U.S. EPA requirements.
2-33	335-7-2-.12(a) 4.	Allows Stage 1 disinfection byproduct data to be used for reduced monitoring determination.
2-48	335-7-2-.16(5)	Clarifies how systems will work together to comply with Stage 2 disinfection byproduct regulations.

**Chapter 335-7-4**

Page	Rule	Rationale
4-2, 3	335-7-4-.03(2), (4), (5)	Requires submittal of permit application information in electronic format.
4-3, 4	335-7-4-.04(1), (3)(a)	Requires submittal of permit application information in electronic format.
4-7	335-7-4-.10(1), (2)(a)	Requires submittal of project completion information in electronic format.
4-9	335-7-4-.11(2)(f) 1., 2.	Requires submittal of monthly operational data reports in electronic format.

**Chapter 335-7-5**

Page	Rule	Rationale
5-8	335-7-5-.13(b)	Administrative Change
5-9	335-7-5-.15(b)	Allows <i>E. coli</i> to be used in addition to total and fecal coliform.
5-10	335-7-5-.17(a)3.	Allows <i>E. coli</i> to be used in addition to fecal coliform.

5-11	335-7-5-.18	Allows <i>E. coli</i> to be used in addition to fecal coliform.
5-14	335-7-5-.22(5) (a)1.(ii)	Clarifies how total coliform samples are invalidated.
5-21	335-7-5-.22(6) (b)3.(i)(I)	Adds references for analytical methods.

### **Chapter 335-7-6**

Page	Rule	Rationale
6-4	335-7-6-.03	Requires submittal of source selection report in electronic format.
6-5	335-7-6-.04(b)	Allows flexibility in treatment requirements when high quality raw water is available.
6-6	335-7-6-.05	Allows flexibility in surface water intake structures.
6-20	335-7-6-.15	Removes auxiliary power requirements for non-community water systems.

### **Chapter 335-7-7**

Page	Rule	Rationale
7-2	335-7-7-.03(a)4.	Adds construction requirements for the separation water mains and sanitary sewer mains.

### **Chapter 335-7-10**

Page	Rule	Rationale
10-10	335-7-10-.05(q) 4.	Clarifies how total coliform samples are invalidated
10-14	335-7-10-.06(12)	Clarifies monitoring requirements for compliance with Stage 2 disinfection byproducts between wholesale and consecutive systems.
10-14	335-7-10-.06(13)	Requires submittal of reports in an electronic format.

### **Chapter 335-7-11**

Page	Rule	Rationale
11-9	335-7-11-.11(a)	Administrative Correction.
11-10	335-7-11-.12(a)	Administrative Correction.
11-13	335-7-11-.13(e)	Administrative Correction.
11-19	335-7-11-.17(2)	Clarifies when timeline for action level exceedances begins.

### **Chapter 335-7-14**

Page	Rule	Rationale
A-1	335-7-14 Appendix A	Technical correction of uranium units to be consistent with U.S. EPA requirements.
B-1	335-7-14 Appendix B	Clarification that the table in Appendix B should be used for consumer confidence reports.